



July 23, 2012

Deane Baker, PE, DPW
Village of DeForest
DeForest, WI 53532

RE: Water Capacity

Dear Deane:

We have reviewed your water system storage capacity relative to serving new lands in the North Business Park. Based on existing and historic water use, we have estimated that your system has capacity to provide an additional 240,000 gallons per day before additional storage facilities may be recommended.

Please let me know if you have further questions.

Sincerely,

Craig E. Mathews, PE

cc: Greg Frahm, Director of Economic Development and Planning